



## Product certificate K98073/03

Issued 2021-01-01

Replaces K98073/02

Page 1 of 2

### Drinking water system components – health effects according to NSF/ANSI/CAN 61

#### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the product:

#### Ball Valve M1

supplied by

### Praher Plastics Austria GmbH

as specified in this product certificate and marked with the Kiwa NSF/ANSI/CAN 61 in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline Manual K15007 for “drinking water system components – health effects according to NSF/ANSI/CAN 61”, dated 15 January 2020.

Ron Scheepers  
Kiwa

*Publication of this certificate is allowed.*

*Advice: consult [www.kiwa.nl](http://www.kiwa.nl) in order to ensure that this certificate is still valid.*

CERTIFICATE

289170315

**Kiwa Nederland B.V.**  
Sir Winston Churchilllaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
info@kiwa.nl  
[www.kiwa.nl](http://www.kiwa.nl)

**Company**  
Praher Plastics Austria GmbH  
Poneggenstraße 5  
4311 Schwertberg  
Austria  
  
Tel. +43 7262 611 78-0  
[www.praher-plastics.com](http://www.praher-plastics.com)



Certification process  
consists of initial and  
regular assessment of:

- quality system
- product

## Drinking water system components – health effects according to NSF/ANSI/CAN 61

### Product specification

The product mentioned below belongs to this certificate.

#### Mechanical devices

Product	Size	Water Contact Temp	Water Contact Material
Ball Valve M1	[1]	cold water [2]	PVC-U, EPDM, PTFE

[1] Certified for a dimensions range DN10/d16/3/8" – DN80/d110  
 [2] Application: for intended use as a ball valve for potable water applications. Product is tested for an end-use temperature of 23 ± 2 °C (73 ± 4 °F).

### Hygienic aspects

#### Approval:

This product is approved on the basis of the requirements set in NSF/ANSI/CAN 61.

#### Kiwa NSF/ANSI/CAN 61 criteria:

The product certification is based on two main criteria. The product shall permanently comply with:

- the product recipe approved during the assessment procedure. The recipe is laid down for the confidentiality reasons undisclosed in the appendix to certificate K98073. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- specific product requirements for the hygienic aspects, laid down in the appendix to certificate K98073. For confidentiality reasons this appendix is not public.

### Marking

The product shall be marked with



Or words **KIWA NSF/ANSI 61**

#### Location of the mark:

- If the dimensions of the products are such that the indications applied to them may impair the product, the products may be marked per package in consultation with the manufacturer, the buyer and Kiwa. Products produced by cutting or die cutting out of sheets may be marked per package.

#### Mandatory marks:

- "Manufacturers name or logo"
- "Product identification (trade name or product type)"
- "Production code"
- "Certificate number"

The realization of the marks as is follows: clearly and indelible.

### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Praher Plastics Austria GmbH
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.